



**MAIN FLOOR PLAN**  
 1826 sq. ft. Living  
 560 sq. ft. Garage  
 228 sq. ft. Rear Porch  
 46 sq. ft. Entry Porch  
 2660 sq. ft. Total

Designed per IBHS 2005 (HRRC)  
 Wind Speed 100 mph  
 Importance Factor 1  
 Wind Exposure B  
 Internal Pressure +/-2  
 Pressure for windows and doors  
 Interior Zone 18.0/-19.5  
 Edge Zone 18.0/-24.1  
 Garage Door 20.4

**WINDOW SCHEDULE**

WINDOW	ROUGH OPENING	DESCRIPTION
25	37-3/4"x63"	Single Hung, Alum. or Vinyl Frame, Dbl. Insulated Glass
35	53-7/8"x63"	Single Hung, Alum. or Vinyl Frame, Dbl. Insulated Glass
1A3	27-1/4"x38-3/8"	Single Hung, Alum. or Vinyl Frame, Dbl. Insulated Glass

Verify rough openings prior to construction. Sizes may vary according to the manufacturer. Contractor shall provide manufacturer's specifications for all windows and exterior doors. Contractor shall provide rough opening sizes for all exterior doors.

**HEADER SCHEDULE**

SYMBOL	SIZE	DESCRIPTION
1	19'4"x16"	Prestressed, Filled, Precast, T19 plf
2	4'6"x8"	Filled, Precast, 2294 plf
3	4'8"x6"	Recessed, Filled, Precast, 1169 plf
4	7'4"x8"	Filled, Precast, 1013 plf
5	5'4"x8"	Filled, Precast, 1669 plf
6	5'10"x8"	Filled, Precast, 1471 plf
7	3'6"x8"	Filled, Precast, 4109 plf
8	6'8"x6"	Recessed, Filled, Precast, 698 plf
9	10'0"x8"	Filled, Precast, 630 plf
10	20'0"x16"	Prestressed, Filled, Precast, 668 plf

Concrete lintels manufactured by MARION MASONRY MATERIALS, INC.

**GARAGE SPECIFICATIONS**

Openings between the garage and residence shall be equipped with solid wood doors not less than 1-3/8" in thickness, solid or honeycomb steel doors not less than 1-3/8" thick or 20 min. fire rated doors.

The garage shall be separated from the residence by not less than 1/2" gypsum board applied to the garage side.

Garages beneath habitable rooms shall be separated from all habitable rooms above by not less than 5/8" Type X gypsum board or equivalent.

The area of floor used for parking of automobiles or other vehicles shall be sloped to facilitate the movement of liquids to a drain or toward the main vehicle entry doorway.

These plans were designed using standard construction practices in Ocala, Florida. They conform to the IBHS 2005 HRRC Supplement and the 2008 National Electric Code and the 2007 Life Safety Code (N.F.P.A.).

Due to variations in local codes and geological conditions, revisions may be required to these plans. It is the builders responsibility to make the necessary revisions to ensure code compliance and structural integrity.

**FLOOR PLAN**

SCALE: 1/4"=1'-0"	REVISIONS	DRAWN BY: K. Wise
DATE: May 18, 2011		JOB NO: 02211
<b>KIM WISE, DESIGNER, INC.</b> 352-236-0055		
RESIDENCE FOR: <i>Immaculate Heart of Mary Catholic Church Rectory</i>	DRAWING NUMBER <b>2</b>	